

杆塔及基础明细表

序号	杆塔编	杆塔位置	杆塔型号	呼称高	定位高差 (m)	转角度数 (°)	塔腿编号	高低腿配置 (m)	基础计算露头 (m)	基础最小埋深	基础形式	施工图编号	备注	地脚螺栓
1	N1	J7+2	V3-2D1Y8-J4-39	39	-2.5	右5° 05′	A	-5	0.3	6.2	扩底桩基础	KDZ122065	预偏值C=D=40mm B=20mm 基础施工不允许爆破	M72-420
							B	-3	0.4	6.1		KDZ122065		
							C	0	0.2	6.3		KDZ122065		
							D	-3	0.7	6.3		KDZ122070		
2	N2	Z1	V3-2D1Y7-Z2-42	42	-1.7	0	A	-5	0.9	5.1	挖孔桩基础	WK10060	基础施工不允许爆破	M36-240
							B	-2	0.6	5.4		WK10060		
							C	0	0.2	5.3		WK10060		
							D	-1	0.2	5.3		WK10060		
3	N3	J7G	V3-2D1Y7-J2-21	21	-0.3	左27° 59′	A	-2	0.6	5.4	扩底桩基础	KDZ101860	预偏值A=B=30mm 基础施工不允许爆破	M56-330
							B	0	0.2	5.8		KDZ101860		
							C	0	0.6	5.4		KDZ101865		
							D	-2	0.4	5.6		KDZ101860		
4	N4	J6G	V3-2D1Y7-J1-30	30	-1.7	右23° 17′	A	0	1.3	5.2	扩底桩基础	KDZ101865	基础施工不允许爆破	M48-290
							B	0	0.4	4.6		KDZ101850		
							C	-2	0.2	4.8		KDZ101850		
							D	-4	0.3	4.7		KDZ101850		
5	N5	J5X	V3-2D1Y7-J4-27	27	-2.3	右64° 11′	A	0	0.2	6.3	扩底桩基础	KDZ122065	预偏值C=D=50mm 基础施工不允许爆破	M64-370
							B	-1	0.4	6.1		KDZ122065		
							C	-3	0.2	6.3		KDZ122065		
							D	-3	0.6	5.9		KDZ122065		
6	N6	Z3XG	220K4010-SJD-36	36	-3.5	0	A	0	0.2	6.8	扩底桩基础	KDZ162470	预偏值C=B=20mm 基础施工不允许爆破	M72-380
							B	0	0.4	6.6		KDZ162470		
							C	-2	0.5	6.5		KDZ162470		
							D	-5	0.2	6.8		KDZ162470		
7	N7	J3XG	220K4010-SJ1-36	36	-2.8	左8° 46′	A	0	0.2	7.3	挖孔桩基础	WK12075	预偏值A=B=35mm C腿方向做长8米甲型堡坎,出土高度2米 基础施工不允许爆破	M60-330
							B	-3	0.2	7.3		WK12075		
							C	-2	1.7	7.3		WK12090		
							D	-2	0.7	7.3		WK12080		
8	N8	Z2G	220K4010-SZ5-54	54	-2.4	0	A	-7	0.3	5.7	扩底桩基础	KDZ101860	BC腿方向做长20米乙型堡坎,出土高度4米 基础施工不允许爆破	M56-320
							B	0	0.2	5.8		KDZ101860		
							C	0	3.9	6.1		KDZ1220100		
							D	-1	0.2	5.8		KDZ101860		
9	N9	J2XG	220K4010-SJD-36	36	-5	右16° 45′	A	0	0.2	6.8	扩底桩基础	KDZ162470	预偏值D=70mm A=C=35mm 基础施工不允许爆破	M72-380
							B	-2	0.2	6.8		KDZ162470		
							C	-8	0.2	6.8		KDZ162470		
							D	-5	0.5	6.5		KDZ162470		
10	N10	J1X	220K4010-SJ1-24	24	-1.9	右85° 14′	A	0	0.5	7	挖孔桩基础	WK12075	预偏值D=50mm A=C=25mm 基础施工不允许爆破	M56-320
							B	-4	0.2	7.3		WK12075		
							C	-4	0.2	7.3		WK12075		
							D	-1	0.2	7.3		WK12075		